



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

2829 4355

圖文傳真
Facsimile

2824 0578

檔號
Reference

(6) in WSD 3321/16 Pt.1 T/J(1309)

12 October 2016

Approval of "FIREX" Galvanized Steel Pipes

Your letter dated 31 August 2016 and subsequent submission received by this department on 30 September 2016 refer.

Having considered the test reports ref. BC-SUMMARY-2016-44 and BC-SUMMARY-2016-45 both issued on 17 August 2016 by Castco Testing Centre Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jiedong Economic Development Testing Zone Tai Feng Qiao Metal Products Co., Ltd.

Country of Origin: China

Brand: Firex

Details of Pipes: Galvanized steel pipes (class medium and class heavy)

Size: DN15, 20, 25, 32, 40, 50, 65, 80, 100, 125, 150

Body Markings:

For class medium:

BS EN 10255:2004(M) / BS EN 1461 W OD (Inch) x
Wall thickness x 1000MM

For class heavy:

BS EN 10255:2004(H) / BS EN 1461 W OD (Inch) x
Wall thickness x 1000MM

Expiry Date:

7 August 2021 (for class medium)

5 August 2021 (for class heavy)

Proviso: The pipes can only be used in fire service plumbing system.

This Authority hereby permits the use of the above pipes in fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fire service plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only