



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/16 Pt.1 T/J(1323)

14 October 2016

Approval of “GUANGDONG 南粵牌” Galvanized Steel Pipes

Your letters dated 14 September 2016 and 29 September 2016 refer.

Having considered the test report ref. BC-SUMMARY-2016-43 issued on 17 August 2016 by Castco Testing Centre Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Municipal Guangdong Steel Tube Co., Ltd.

Country of Origin: China

Brand: Guangdong 南粵牌

Details of Pipes: Galvanized steel pipes (class medium)

Size: DN32, 40, 65, 80, 100, 150

Body Markings: 廣州南粵 GB/T3091-2008 DN(Inch) x 6000mm

Expiry Date: 5 August 2021

Proviso: The pipes can only be used in fire service plumbing system.

This Authority hereby permits the use of the above pipes in fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fire service plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only