



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

2829 4355

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/16 Pt.1 T/J(1345)

14 October 2016

Approval of "SEAH" Black Steel Pipe

Your letters dated 21 September 2016 and 3 October 2016 refer.

Having considered the test report ref. 150405ST160586 issued on 14 September 2016 by Fugro Technical Services Limited., this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SeAH Steel Corp

Country of Origin: Korea

Brand: SeAH

Details of Pipe: Black Steel Pipe

Size: DN200

Body Marking: SeAH SeAH STEEL EW EN10217-1:2002 P265TR1
C2 200MM x 6.3MM x 6M MADE IN KOREA KHK

Expiry Date: 26 July 2021

Proviso: The pipe can only be used in fire service plumbing system.

This Authority hereby permits the use of the above pipe in fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fire service plumbing systems.

For the use of the pipe in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only