



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件

e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

2829 4355

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/16 Pt.1 T/J(1401)

1 November 2016

Approval of "SEAH" Galvanized Steel Pipes

Your letters dated 3 October 2016 and 24 October 2016 refer.

Having considered the test report ref. 161440ST160585(1)A issued on 19 October 2016 by Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	SeAH Steel Vina Corporation
Country of Origin:	Vietnam
Brand:	SeAH
Details of Pipes:	Galvanized steel pipes (class medium and class heavy)
Size:	20mm
Body Markings:	For class medium: SĕAH SeAH Steel EN 10255:2004 SERIES MEDIUM W 20MM X 6M MADE IN VIETNAM KHK VN

For class heavy:
SđAH SeAH Steel EN 10255:2004 SERIES
HEAVY W 20MM X 6M MADE IN VIETNAM
KHK VN

Expiry Date: 10 October 2021

Proviso: The pipes can only be used in fresh water fire service plumbing system.

This Authority hereby permits the use of the above pipes in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only