



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/16 Pt.1 T/J(1491)

25 November 2016

Approval of "EMPIRE" Check Valves

Your letters ref. WSD/AP-31102016-1 and WSD/AP-31102016-1(1) dated 31 October 2016 and 15 November 2016 respectively refer.

Having considered the test report ref. 163717ST160801(1)B issued on 9 November 2016 by Fugro Technical Services Limited, this Authority accepts that the fittings described below complies with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Empire Specialty Inc

Country of Origin: China

Brand: Empire

Details of Fittings: Stainless steel wafer type silent check valve

Model: 291

Size: 40mm, 50mm, 65mm, 80mm, 100mm, 150mm, 200mm

Body Markings: Empire size in DN size in inch PN40

Expiry Date:

10 August 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fire services subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



291