



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/16 Pt.1 T/J(1599)

22 December 2016

Approval of "VIR" Stop Valves

Your letters ref. GWL/16/00009 and GWL/16/00009-R1 dated 17 November 2016 and 13 December 2016 respectively refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
VIR	560 (½")	J18245Cr1	25 August 2016
VIR	560 (¾")	J18245Br1	25 August 2016
VIR	560 (1")	J18245Ar1	25 August 2016

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Taizhou VIR Valve Manufacturing Co Ltd

Country of Origin: China

Brand: VIR

Details of Fittings: Copper alloy loose jumper stopcock

Model: 560
Size: ½", ¾", 1"
Body Markings:  size in inch 
Expiry Date: 11 August 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fire services subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.


Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



560