



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件

e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

2829 4355

圖文傳真
Facsimile

2824 0578

檔號
Reference

(5) in WSD 3321/16 Pt.1 T/J(1616)

30 December 2016

Approval of "GROHE" Bath Mixer

Your letters ref. WRC/1244 dated 28 November 2016, ref. C-WSD/0223 dated 7 December 2016 and ref. C-WSD/0226 dated 14 December 2016 refer.

Having considered the test report ref. J20965 issued on 22 November 2016 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Grohe AG

Country of Origin: Germany

Brand: Grohe

Details of Fitting: 3/4" 5-hole bath combination supplied with 5 nos of DN13 1/2" X 3/4" flexible connection hoses, 1 no of DN8 1/2" X 3/8" flexible connection hose (manufactured by Neoperl GmbH; model: Neoflex SPX DN13 G1/2", DN8 G1/2") approved by UK's WRAS under Certificate No. 1506306

Model: 19919XXX
(where the digits "XXX" denote the code of colour variants)

Body Markings: **GROHE**


Expiry Date: 9 November 2021 (for mixer)
30 June 2020 (for hose)

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



19919XXX