



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/16 Pt.1 T/J(1606)

11 January 2017

Approval of "BAIN D'OR" Thermostatic Mixing Valves

Your letters ref. BE/L794/16 dated 24 November 2016 and ref. BE/L830/16 dated 22 December 2016 refer.

Having considered the test report ref. J20561r1 issued on 14 December 2016 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Bain d'Or

Country of Origin: China

Brand: Bain d'Or

Details of Fitting: 1/2" Thermostatic mixing valve for shower panel supplied with one pair of YUHUAN YAOYAO METAL HOSE CO., LTD B-62: S F1/2" X F1/2" (DN13) STAINLESS STEEL BRAIDED EPDM RUBBER LINED FLEXIBLE HOSE ASSEMBLIES approved by UK's WRAS under ref. 1512315

Model: BDR-MX-SL-18-SS & BDR-MX-SL-18

Body Markings: **Bain d'Or**

Expiry Date: 16 October 2021 (for valves)
31 December 2020 (for hose)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



BDR-MX-SL-18-SS/ BDR-MX-SL-18