



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(2) in WSD 3321/16 Pt.1 T/J(1712)

12 January 2017

Approval of "GROHE" Bath Mixer

Your letter ref. WRC/1261 dated 19 December 2016 refers.

Having considered the test report ref. J18990 issued on 13 December 2016 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Grohe AG

Country of Origin: Germany

Brand: Grohe

Details of Fitting:

- 1/2" 4-hole bath mixer supplied with
- 1) 2 pieces of NPI Italia SrL - Platinox SLP DN13
G1/2" x 3/4" stainless steel braided silicone lined
flexible hoses approved by UK's WRAS under
certificate no. 1511044
- 2) 2 pieces of Neoperl GmbH - Neoflex SPX DN13
G1/2" x 1/2" flexible connection hoses approved by
UK's WRAS under certificate no. 1506306

- 3) 1 piece of Neoperl GmbH - Neoflex SPX DN8
G3/8" x G1/2" flexible connection hoses approved
by UK's WRAS under certificate no. 1506306

Model: 19936XXX
(where the digits "XXX" denote the code of colour
variants)

Body Markings: 

Expiry Date: 11 December 2021 (for mixer)
30 November 2020 (for hose 1)
30 June 2020 (for hose 2 & 3)

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



19936XXX