



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/16 Pt.1 T/J(1676)

16 January 2017

Approval of "VP" Check Valves

Your letters dated 12 December 2016 and 6 January 2017 refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
VP	VP-460 (32mm)	J20702A	18 November 2016
VP	VP-460 (40mm)	J20702B	18 November 2016
VP	VP-460 (50mm)	J20702C	18 November 2016

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hershey Valve Co Ltd

Country of Origin: Taiwan

Brand: VP

Details of Fitting: uPVC ball check valve

Model: VP-460

Size: 32mm, 40mm, 50mm

Body Markings:

Size	Description		
32mm			FLOW DIRECTION 32-1¼"
40mm			FLOW DIRECTION 40-1½"
50mm			FLOW DIRECTION 50-2"

Expiry Date: 17 October 2021

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



VP-460