



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(10) in WSD 3321/16 Pt.1 T/J(1626)

8 February 2017

Approval of "KITZ" Check Valves

Your letter ref. BEP/EME/LET/MF211 dated 25 November 2016 and subsequent submission received by this department on 18 January 2017 refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Kitz	RF (20mm)	J20666A	21 November 2016
Kitz	RF (25mm)	J20666B	21 November 2016
Kitz	RF (32mm)	J20666C	21 November 2016
Kitz	RF (40mm)	J20666D	21 November 2016
Kitz	RF (50mm)	J20666E	21 November 2016

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kitz

Country of Origin: Thailand

Brand: Kitz

Details of Fitting: Bronze lift check valve

Model: RF

Size: 20mm, 25mm, 32mm, 40mm, 50mm

Body Marking: For 50mm:
KITZ 6 10K size in inch ↑

For others:
KITZ 5 10K size in inch ↑

Expiry Date: 21 August 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fire services subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



RF