



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(2) in WSD 3321/17 Pt.1 T/J(54)

10 February 2017

Approval of “ASAHI” uPVC Ball Valves

Your letter ref. ASAHIVALVES20170119/01 dated 23 January 2017 refers.

Having considered the test report ref. BC-SUMMARY-2017-7 issued on 17 January 2017 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Asahi Yukizai Corporation

Country of Origin: Japan

Brand: Asahi

Details of Fittings:

1. uPVC Grey Compact Ball Valve Type 27 – Socket Ends
Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm
2. uPVC Grey Compact Ball Valve Type 27 – Thread Ends
Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm

3. uPVC White Compact Ball Valve Type 27 – Socket Ends
Size: 15mm, 20mm

Body Markings:

 ASAHI AV BALL VALVE
MADE IN JAPAN SIZE PVC

Expiry Date:

12 December 2021

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.


Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Grey Compact Ball Valve Type 27 - Socket Ends/
Grey Compact Ball Valve Type 27 - Thread Ends



White Compact Ball Valve Type 27 - Socket Ends