



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/16 Pt.1 T/J(1758)

14 February 2017

Approval of "N.U" Stainless Steel Pipes

Your letter ref. DPPL/RC/001/2017 dated 18 January 2017 refers.

Having considered the test report ref. BC-SUMMARY-2016-104 issued on 11 January 2017 by Castco Testing Centre Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shenzhen Artway Piping Company Limited

Country of Origin: China

Brand: N.U

Details of Pipe: Stainless steel pipe - series 2 (316L)

Model & Size:
PP3160151M - 15mm
PP3160221M - 22mm
PP3160281M - 28mm
PP3160351M - 35mm
PP3160421M - 42mm
PP3160541M - 54mm
PP3160761M - 76.1mm

PP3160881M - 88.9mm
PP3161081M - 108mm

Body Markings: N.U DOUBLE PRESS SUS316L
EN10312 SERIES II

Expiry Date: 8 December 2021

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only