



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/17 Pt.1 T/J(6)

10 March 2017

Approval of “Y.W (英華牌)” Mechanical Mixer and Taps

Your letter dated 20 December 2016 and subsequent submission received by this department on 2 March 2017 refer.

Brand	Model No.	Nutek Test Report Ref.	Issuance Date
Y.W (英華牌)	YW-8912	J20552A	2 Dec 2016
Y.W (英華牌)	YW-6808	J20553Ar1	12 Jan 2017
Y.W (英華牌)	YW-8800	J20554A	16 Dec 2016

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: 江門市江海區堅美樓宇設備廠

Country of Origin: China

Brand: Y.W (英華牌)

Details of Fitting: 1. 1/2" Single lever basin mixer
Model: YW-8912

2. 1/2" Single lever basin tap
Model: YW-6808
3. 1/2" Deck mounted sink tap
Model: YW-8800

Body Markings:

For YW-8912:  Y.W.

For YW-6808: Y.W.

For YW-6808: 

Expiry Date:

23 November 2021 (for YW-8912)

4 September 2021 (for YW-6808)

7 December 2021 (for YW-8800)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



YW-8912



YW-6808



YW-8800