



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(6) in WSD 3321/16 Pt.1 T/J(1681)

14 March 2017

Approval of "DFP" uPVC Pipes

Your letters dated 7 December 2016, 14 February 2017 and 27 February 2017 refer.

Brand	Size	Fugro Test Report Ref.	Issuance Date
DFP	3/4"	165944ST170004(1)A	22 Feb 2017
DFP	1"	165944ST170004(2)A	22 Feb 2017
DFP	1 1/4"	165944ST170004(3)A	22 Feb 2017
DFP	1 1/2"	165944ST170004(4)A	22 Feb 2017
DFP	2"	165944ST170004(5)A	22 Feb 2017
DFP	3"	165944ST170004(6)A	22 Feb 2017
DFP	4"	165944ST170004(7)A	22 Feb 2017
DFP	6"	165944ST170004(8)A	22 Feb 2017
DFP	8"	165944ST170004(9)A	22 Feb 2017
DFP	10"	165944ST170004(10)A	22 Feb 2017
DFP	12"	165944ST170004(11)A	22 Feb 2017

Having considered the above test reports and ref. 161954EN161497A issued on 17 January 2017 by Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kunshan Shie Yu Valve Co Ltd
Country of Origin: China
Brand: DFP
Details of Pipes: uPVC Sch.80 pipe in grey colour (Class E)
Size: ¾", 1", 1¼", 1½", 2", 3", 4", 6", 8", 10", 12"
Body Markings: KUNSHAN SHIE YU VALVE CO., LTD. SCH80
size in inch UPVC ASTM D1785 TYPE 1
GRADE 1 pressure rating in PSI W.P. @ 73.4 °F
(WATER) production date
Expiry Date: 24 October 2021

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only