



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(135)

15 March 2017

Approval of "GROHE" Concealed Valve

Your letters ref. WRC/1294 dated 21 February 2017 and ref. C-WSD/0231 dated 1 March 2017 refer.

Having considered the test report ref. J21174 issued on 6 February 2017 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Grohe AG

Country of Origin: Portugal

Brand: Grohe

Details of Fitting: 3/4" Concealed valve body

Model: 29802000 with 45885000

Body Markings: P-IX1458/I KIWA B3 DR ←

Expiry Date: 23 January 2022

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fire services subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



29802000 with 45885000