



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

2829 4355

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/16 Pt.1 T/J(1735)

23 March 2017

Approval of "ZENZO" Concealed Valves and Mixer

Your letters dated 23 December 2016 and 3 March 2017 refer.

Having considered the test reports ref. 154191ST160756(2)A, 154191ST160756(3)A and 154191ST160756(4)A all issued on 20 February 2017 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Heshan City Jearly Enterprises Co Ltd

Country of Origin: China

Brand: Zenzo

Details of Fittings:

1. 1/2" Single lever sink mixer
Model: 4622502C
2. 1/2" Conceal shower valve
Model: 4643502C

3. 1/2" Conceal shower valve with diverter
Model: 4643503C

Body Markings: ZENZO

Expiry Date: 22 September 2021 (for 4643502C)
9 December 2021 (for 4622502C & 4643503C)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,




(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



4622502



4643502C



4643503C