



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/17 Pt.1 T/J(229)

24 March 2017

Approval of "WELSON" Check Valves

Your letter ref. WEL1600-AP02272017 dated 27 February 2017 refers.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
Welson	1600-32 (32mm)	164641ST161223	21 Feb 2017
Welson	1600-40 (40mm)	164641ST161223(1)	21 Feb 2017
Welson	1600-50 (50mm)	164641ST161223(2)	21 Feb 2017
Welson	1600-65 (65mm)	164641ST161223(3)	21 Feb 2017
Welson	1600-80 (80mm)	164641ST161223(4)	21 Feb 2017
Welson	1600-100 (100mm)	164641ST161223(5)	21 Feb 2017

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Welson Metal & Sanitary Ware MFY

Country of Origin: China

Brand: Welson

Details of Fittings: Stainless steel wafer type check valve

Model and Size: 1600-32 – 32mm
1600-40 – 40mm
1600-50 – 50mm
1600-65 – 65mm
1600-80 – 80mm
1600-100 – 100mm

Body Markings: WELSON SS 316 size in DN ➡

Expiry Date: 27 December 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fire services subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply system mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



1600-32/ 1600-40/ 1600-50/ 1600-65/ 1600-80/ 1600-100