



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/17 Pt.1 T/J(101)

10 April 2017

Approval of "NFK" Flexible Joints

Your letters ref. WL-17/005 and WL-17/010 dated 10 February 2017 and 24 March 2017 respectively refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
NFK	NK-6300 (20mm)	165311ST161201B	20 Mar 2017
NFK	NK-6300 (25mm)	165311ST161201(1)B	20 Mar 2017
NFK	NK-6300 (32mm)	165311ST161201(2)B	20 Mar 2017
NFK	NK-6300 (200mm)	165311ST161201(3)B	20 Mar 2017
NFK	NK-6300 (250mm)	165311ST161201(4)B	20 Mar 2017
NFK	NK-6300 (300mm)	165311ST161201(5)B	20 Mar 2017

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Nangoku Flexible Hose Industry Co Ltd

Country of Origin: Japan

Brand: NFK

Details of Fitting: Stainless steel flexible joint

Model: NK-6300

Size: 20mm, 25mm, 32mm, 200mm, 250mm, 300mm

Body Markings: NFK NK-6300 PN16 size in DN

Expiry Date: 29 December 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fire services subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply system mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



NK-6300