



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(338)

24 April 2017

Approval of “RENÉ” Sensor Taps

Your letters ref. DR/WSD/TT/L/17/3/32 dated 24 March 2017 and ref. DR/WSD/TT/L/17/4/01 dated 3 April 2017 refer.

Having considered the test report ref. J21059r1 issued on 31 March 2017 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yocoss Electronic Equipment Co Ltd

Country of Origin: China

Brand: RENÉ

Details of Fitting: 1/2" Solar sensor tap supplied with one piece of Fanski Group Inc DG10E-UKWR-XXX-L range of hose assemblies approved by UK's WRAS under ref. 1306022

Model: C351X-I, C351X-II, C351X-III
(where the digit “X” denotes the operating method)

Body Markings:

RENÉ

Expiry Date:

28 February 2022

(for tap)

30 June 2018

(for hose)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."


A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



C351X-I/ C351X-II/ C351X-III