



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(406)

9 May 2017

Approval of "HYUNDAI STEEL" Galvanized Steel Pipes

Your letters ref. LP17/005 and LP17/006 dated 12 April 2017 and 20 April 2017 respectively refer.

Brand	Class (Size)	Nutek Test Report Ref.	Issuance Date
Hyundai Steel	Medium (25mm)	J21335A	7 Apr 2017
Hyundai Steel	Medium (32mm)	J21335B	7 Apr 2017
Hyundai Steel	Medium (40mm)	J21335C	7 Apr 2017
Hyundai Steel	Medium (50mm)	J21335D	7 Apr 2017
Hyundai Steel	Medium (65mm)	J21335E	7 Apr 2017
Hyundai Steel	Medium (80mm)	J21335F	7 Apr 2017
Hyundai Steel	Medium (100mm)	J21335G	7 Apr 2017
Hyundai Steel	Medium (150mm)	J21335H	7 Apr 2017
Hyundai Steel	Heavy (150mm)	J21336	7 Apr 2017

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hyundai Steel Company

Country of Origin: Korea

Brand: Hyundai Steel

Details of Pipes:

1. Galvanized steel pipes; class medium
Size: 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm
2. Galvanized steel pipes; class heavy
Size: 150mm

Body Markings:

For class medium:
MADE IN KOREA HYUNDAI STEEL YFC
BS1387 M / BS EN 10255 M / ISO 65M-E
size x length HEAT NO.

For class heavy:
MADE IN KOREA HYUNDAI STEEL YFC
BS1387 H / BS EN 10255 H / ISO 65H-E
size x length HEAT NO.

Expiry Date: 19 March 2022

Proviso: The pipes can only be used in fresh water fire service plumbing system.

This Authority hereby permits the use of the above pipes in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only