



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(405)

16 May 2017

Approval of "SHOWA" Gate Valves

Your letters ref. WL-17/014 and WL-17/016 dated 14 April 2017 and 26 April 2017 respectively refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
Showa	Fig. 35 (65mm)	164431ST160998A	22 Apr 2017
Showa	Fig. 35 (80mm)	164431ST160998(1)A	22 Apr 2017
Showa	Fig. 35 (100mm)	164431ST160998(2)	7 Apr 2017
Showa	Fig. 35 (150mm)	164431ST160998(3)	7 Apr 2017
Showa	Fig. 35 (200mm)	164431ST160998(4)	7 Apr 2017
Showa	Fig. 35 (250mm)	164431ST160998(5)	7 Apr 2017

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Showa Valve Co Ltd

Country of Origin: China

Brand: Showa

Details of Fittings: Cast iron gate valve with epoxy powder coating under WRAS approval no. 1701509

Model: Fig. 35

Size: 65mm, 80mm, 100mm, 150mm, 200mm, 250mm

Body Markings:

Size in DN	Production Year
CI	EN1074-2
	PN16
	Production Code

Expiry Date: 1 December 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Fig. 35