



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4355

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (4) in WSD 3321/17 Pt.1 T/J(177)

22 May 2017

### Approval of "PO SING" Galvanized Steel Pipe

Your letter dated 20 February 2017 and subsequent submission received by this department on 4 May 2017 refer.

Having considered the test report ref. PMA 70258 issued on 25 January 2017 by ETS-Testconsult Ltd., this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Po Sing Steel Pipe

**Country of Origin:** China

**Brand:** Po Sing

**Details of Pipe:** 200mm Galvanized steel pipe

**Body Markings:**  Po Sing Steel Pipe (EW) BSEN 10217-1  
P265TR1 219.1MM x 5.6MM x 6.00M

**Expiry Date:** 14 December 2021

**Proviso:** The pipe can only be used in fresh water fire service plumbing system.

This Authority hereby permits the use of the above pipe in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the pipe in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)  
for Water Authority

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only