



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/17 Pt.1 T/J(531)

29 May 2017

Approval of "ICV" Check Valves

Your letter ref. SP/ADM/OSL/L/2017/012 dated 11 May 2017 refers.

Having considered the test report ref. PMA71839 issued by ETS-Testconsult Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: IC Valve (Nanjing) Co Ltd

Country of Origin: China

Brand: ICV

Details of Fitting: Ductile iron swing check valve (with epoxy powder coating under WRAS approval no. 1701509)

Model and Size:

41-065-21-018	– 65mm
41-080-21-018	– 80mm
41-100-21-018	– 100mm
41-150-21-018	– 150mm

Body Markings:

For model 41-065-21-018:



DN65 PN16 GGG GJS

For others:



Size in DN PN16 GJS 500-7

Expiry Date:

31 January 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,

A handwritten signature in black ink, appearing to be 'm k'.

(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



41-065-21-018/ 41-080-21-018/
41-100-21-018/ 41-150-21-018