



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(612)

28 June 2017

Approval of "KC" UPVC Pipes

Your letters dated 2 June 2017 and 12 June 2017 refer.

Having considered the test reports ref. 164167ST161072, 164167ST161072(1) and 164167ST161072(2) all issued on 26 May 2017 by Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kubota ChemiX Co Ltd

Country of Origin: Japan

Brand: KC

Details of Pipes: uPVC Pipes in grey colour

Model and Size:
KCV150 – 150mm
KCV200 – 200mm
KCV250 – 250mm

Body Markings:

150 MM	∞PVC-U-341'9 C3K (A) (B) JW JIS K6742 · VP150 14 KC 6'244'47 JW0306005 KO 56 · 1607· 22H CZ O
200 MM	∞PVC-U (A) (B) JW JIS K6741 · VP200 14 KC 6'244'47 JW0506001 KS S-1 · 1608:0112
250 MM	∞PVC-U (A) (B) JW JIS K6741 · VP250 14 KC 6'244'47 JW0306004 KO 31 · 1607:2918

Expiry Date: 6 March 2022

Proviso: As the pipes have not been tested for use in contact with water intended for human consumption, the pipes can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipes in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in flushing water plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only