



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(6) in WSD 3321/17 Pt.1 T/J(628)

5 July 2017

Approval of "WAH CHIT" Black Steel Pipes

Your letters ref. L171009, L171013 and L171014 dated 7 June 2017, 15 June 2017 and 19 June 2017 respectively refer.

Having considered the test report ref. J21468r1 issued on 14 June 2017 by Nutek Systems (HK) Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangdong Walsall Steel Pipe Industrial Co Ltd

Country of Origin: China

Brand: Wah Chit

Details of Pipes: Black steel pipe

Size: 200mm, 250mm, 300mm, 350mm

Body Markings:  WAH CHIT Size in DN OD x length EW
BSEN10217-1 Steel grade no. Production code

Expiry Date:

16 May 2022

Proviso: The pipes can only be used in fresh water fire service plumbing system.

This Authority hereby permits the use of the above pipes in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only