



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

2829 4355

圖文傳真
Facsimile

2824 0578

檔號
Reference

(5) in WSD 3321/17 Pt.1 T/J(715)

13 July 2017

Approval of "KURIMOTO" Ductile Iron Pipes

Your letters ref. 640/2017 and 661/2017 dated 16 June 2017 and 22 June 2017 respectively refer.

Having considered the test report ref. PMA72443 issued on 24 May 2017 by ETS-Testconsult Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kurimoto Ltd

Country of Origin: Taiwan

Brand: Kurimoto

Details of Pipes: K9 Ductile iron socket and spigot pipe with internal cement lining under WRAS approval no. 1707512

Size: 350mm, 400mm, 450mm, 500mm, 600mm

Body Markings: KURIMOTO **X** BSEN 545 size x length K9

Expiry Date:

20 May 2022

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only