



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(2) in WSD 3321/17 Pt.1 T/J(712)

19 July 2017

Approval of "FIORE" Mechanical Mixers

Your letter dated 15 June 2017 refers.

Brand	Model No.	Castco Test Report Ref.	Issuance Date
Fiore	XXYY8127	BC-SUMMARY-2017-53	24 May 2017
Fiore	XXYY8126	BC-SUMMARY-2017-53	24 May 2017
Fiore	XXYY8120	BC-SUMMARY-2017-60	2 May 2017
Fiore	XXYY8152	BC-SUMMARY-2017-68	24 May 2017

Having considered the above test reports issued by the Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Fiore Rubinetterie Srl

Country of Origin: Italy

Brand: Fiore

Details of Fittings:

1. 3/8" Single lever basin mixer
Model: XXYY8127, XXYY8126, XXYY8120
(where the digit "XX" denote the code of handles and "YY" denote the code of finishing)
2. 1/2" Single lever bath mixer
Model: XXYY8152
(where the digit "XX" denote the code of handles and "YY" denote the code of finishing)

Body Markings:

FIORE MADE IN ITALY

Expiry Date:

12 May 2022 (for model XXYY8152)
6 April 2022 (for others)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



XXY8152



XXY8120



XXY8127



XXY8126