



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/17 Pt.1 T/J(803)

25 July 2017

Approval of "KITZ" Check Valves

Your letter ref. BEP/EME/LET/MF267 dated 23 June 2017 refers.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Kitz	PN25SWNBME (65mm)	J21381A	15 Jun 2017
Kitz	PN25SWNBME (80mm)	J21381B	15 Jun 2017
Kitz	PN25SWNBME (100mm)	J21381C	15 Jun 2017

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kitz

Country of Origin: China

Brand: Kitz

Details of Fittings: Ductile iron wafer type check valve

Model: PN25SWNBME

Size: 65mm, 80mm, 100mm

Body Markings: size in DN PN25 → DI →

Expiry Date: 30 May 2022

Proviso: The fittings can only be used in non-potable water plumbing system.

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



PN25SWNBME