



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4355

圖文傳真  
Facsimile 2824 0578

檔號  
Reference ( 4 ) in WSD 3321/17 Pt.1 T/J(564)

31 July 2017

### Approval of "HANSA" Mechanical Mixers

Your letters both ref. SL20170509 dated 9 May 2017 and 22 June 2017 refer.

| Brand | Model No. | Castco Test Report Ref. | Issuance Date |
|-------|-----------|-------------------------|---------------|
| Hansa | 51402293  | BC-SUMMARU-2017-54      | 19 Apr 2017   |
| Hansa | 51442193  | BC-SUMMARY-2017-55      | 19 Apr 2017   |

Having considered the above test reports issued by the Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Hansa Metallwerke AG

**Country of Origin:** Germany

**Brand:** Hansa

**Details of Fittings:** 1. 3/8" Single lever basin mixer  
Model: 51402293

2. 1/2" Single lever bath mixer  
Model: 51442193

**Body Markings:**



**Expiry Date:**

6 April 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the fresh water supply systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'Chan Chung Kun'.

(CHAN Chung Kun)  
for Water Authority

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only



Model No: 5140 2293



Model No: 5144 2193