



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

( 2 ) in WSD 3321/17 Pt.1 T/J(861)

1 August 2017

### Approval of "ROCA" Mechanical Mixers

Your letter ref. RSL-Cert-17003 dated 30 June 2017 refers.

| Brand | Model No. | Nutek Test Report Ref. | Issuance Date |
|-------|-----------|------------------------|---------------|
| Roca  | 5A3031xxx | J20352                 | 11 May 2017   |
| Roca  | 5A3C09xxx | J20354                 | 5 Apr 2017    |

Having considered the above test reports issued by the Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Roca Sanitaryware (Suzhou) Co Ltd

**Country of Origin:** China

**Brand:** Roca

**Details of Fittings:** 1. 1/2" Basin mixer  
Model: 5A3031xxx  
(where "xxx" denote the code of finish)

2. 1/2" High basin mixer  
Model: 5A3C09xxx  
(where "xxx" denote the code of finish)

**Body Markings:**

**Roca**

**Expiry Date:**

26 April 2022 (for model 5A3031xxx)

26 February 2022 (for model 5A3C09xxx)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)  
for Water Authority

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only



**5A3031xxx**



**5A3C09xxx**