



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/17 Pt.1 T/J(952)

16 August 2017

Approval of "TOWNTUBE" Galvanized Steel Pipe

Your letter dated 12 July 2017 and 17 July 2017 refer.

Having considered the test report ref. J21535 issued on 7 July 2017 by Nutek System (HK) Ltd., this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jie Sheng Fa Industry & Trading Co Ltd

Country of Origin: China

Brand: Towntube

Details of Pipe: 200mm Galvanized steel pipe

Body Markings: TOWNTUBE BSEN10217 SERIES MEDIUM W
DN200mm x 1M

Expiry Date: 31 May 2022

Proviso: The pipe can only be used in fresh water fire service plumbing system.

This Authority hereby permits the use of the above pipe in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the pipe in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(Roger WONG)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only