



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/17 Pt.1 T/J(760)

22 August 2017

Approval of “KWC” Kitchen Mixers

Your letters all ref. WSD/AAHLKWC21062017 dated 21 June 2017, 30 June 2017 and 3 August 2017 refer.

Brand	Model No.	Nutek Test Report Ref.	Issuance Date
KWC	10.191.003.000FL	J19458r1	14 Jun 2017
KWC	10.201.102.000FL	J19459r1	14 Jun 2017
KWC	10.361.033.000FL	J19460r1	14 Jun 2017

Having considered the above test reports issued by the Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: KWC

Country of Origin: Switzerland

Brand: KWC

Details of Fitting:	3/8" Single lever kitchen mixer supplied with 1) 2 nos. of Neoperl GmbH Neoflex Spx range of flexible hose assemblies approved by UK's WRAS under ref. 1506306 and 2) 1 no. of flexible hose claimed to be approved by Material test conducted by Nutek Systems (HK) Limited (test report number: J21185r1)	
Model:	10.191.003.000FL, 10.201.102.000FL & 10.361.033.000FL	
Body Markings:	For 10.191.003.000FL:  For 10.201.102.000FL & 10.361.033.000FL: 	
Expiry Date:	15 May 2022	(for mixer + hose (2))
	30 June 2020	(for hose (1))

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,




(Roger WONG)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



10.191.003.000FL



10.201.102.000FL



10.361.033.000FL