



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/17 Pt.1 T/J(1152)

18 September 2017

Approval of “VALVEMAKER” Gate Valves

Your letter ref. VM/WSD/GA/20170825 dated 25 August 2017 refers.

Having considered the test reports ref. BC-SUMMARY-2017-2 and EN0160610-16 issued on 4 August 2017 and 19 September 2016 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Yantai Valve Factory
Country of Origin:	China
Brand:	Valvemaker
Details of Fitting:	Ductile iron metal seated gate valve (with epoxy coating under test report ref. EN0160610-16)
Model:	16-GV (Hand Wheel) 16-GV (Stem Cap)

Size: 50mm, 65mm, 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

Body Markings: V-MAKER 20__ (Year of Manufacture) size in DN
SG CF PN16 BS5163-1 EN1074-2

Expiry Date: 8 August 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



16-GV (Hand Wheel)



16-GV (Stem Cap)