



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/17 Pt.1 T/J(1200)

29 September 2017

Approval of "HKS" Strainers

Your letters ref. L17-0804 and L17-0904 dated 30 August 2017 and 8 September 2017 respectively refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
HKS	SV15YSC-6 (15mm)	172244ST170423	21 Aug 2017
HKS	SV20YSC-6 (20mm)	171230ST170423(1)	21 Aug 2017
HKS	SV25YSC-6 (25mm)	172244ST170423(2)	21 Aug 2017
HKS	SV32YSC-6 (32mm)	171230ST170423(3)	21 Aug 2017
HKS	SV40YSC-6 (40mm)	172244ST170423(4)	21 Aug 2017
HKS	SV50YSC-6 (50mm)	171230ST170423(5)	21 Aug 2017

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: HK Steel Ltd

Country of Origin: China

Brand: HKS

Details of Fittings: Stainless steel Y-strainer

Model and Size: SV15YSC-6 – 15mm
SV20YSC-6 – 20mm
SV25YSC-6 – 25mm
SV32YSC-6 – 32mm
SV40YSC-6 – 40mm
SV50YSC-6 – 50mm

Body Markings:  316 size in inch →

Expiry Date: 5 June 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.


Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



SV15YSC-6/ SV25YSC-6/ SV40YSC-6/	SV20YSC-6/ SV32YSC-6/ SV50YSC-6
---	--