



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (8) in WSD 3321/17 Pt.1 T/J(1091)

17 October 2017

Approval of “ERA” uPVC Pipes

Your letter dated 9 August 2017 and subsequent submission received by this department on 29 September 2017 refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
ERA	BS15 (15mm)	170535ST1702384(2)	10 Aug 2017
ERA	BS20 (20mm)	170535ST1702384	10 Aug 2017
ERA	BS25 (25mm)	170535ST1702384(1)	10 Aug 2017
ERA	BS32 (32mm)	170535ST1702384(3)	10 Aug 2017
ERA	BS40 (40mm)	170535ST1702384(4)	10 Aug 2017
ERA	BS50 (50mm)	170535ST1702384(5)	10 Aug 2017
ERA	BS65 (65mm)	170535ST1702384(6)	10 Aug 2017
ERA	BS80 (80mm)	170535ST1702384(7)	12 Aug 2017
ERA	BS100 (100mm)	170535ST1702384(8)	10 Aug 2017
ERA	BS150 (150mm)	170535ST1702384(9)	10 Aug 2017

Having considered the above test reports and ref. 170535EN170839A issued on 12 September 2017 by Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yonggao Co Ltd

Country of Origin: China

Brand: ERA

Details of Pipes: uPVC pipes in white colour

Model	Size (mm)
BS15	15
BS20	20
BS25	25
BS32	32
BS40	40
BS50	50
BS65	65
BS80	80
BS100	100
BS150	150

Body Markings: ERA PVC-U size in mm CLASS E BS3505

Expiry Date: 9 April 2022

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only