



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(1271)

23 October 2017

Approval of "PEGLER YORKSHIRE" Ball Valves

Your letters dated 19 September 2017 and 25 September 2017 refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Pegler Yorkshire	PB100HYG (½")	J20953A	28 Dec 2016
Pegler Yorkshire	PB100HYG (¾")	J20953B	28 Dec 2016
Pegler Yorkshire	PB100HYG (1")	J20953C	28 Dec 2016
Pegler Yorkshire	PB100HYG (1¼")	J20953D	28 Dec 2016
Pegler Yorkshire	PB100HYG (1½")	J20953E	28 Dec 2016
Pegler Yorkshire	PB100HYG (2")	J20953F	28 Dec 2016

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Pegler Yorkshire

Country of Origin: UK

Brand: Pegler Yorkshire

Details of Fittings: Brass ball valve
Model: PB100HYG
Size: ½", ¾", 1", 1¼", 1½", 2"
Body Markings: PEGLER ENGLAND size in inch PN25
Expiry Date: 8 December 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



PB100HYG