



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/17 Pt.1 T/J(1257)

24 October 2017

Approval of "RICHFORD" Mechanical Mixers

Your letter dated 12 September 2017 and subsequent submission received by this department on 11 October 2017 refer.

Brand	Model No.	Nutek Test Report Ref.	Issuance Date
Richford	RF19601	J21741r1	26 Sept 2017
Richford	RF19604A	J21742r1	26 Sept 2017
Richford	RF19605A	J21743r1	26 Sept 2017

Having considered the above test reports issued by the Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Richford Group Ltd

Country of Origin: China

Brand: Richford

Details of Fittings: 1. 3/8" Single lever basin mixer
Model: RF19601

2. 1/2" Bath/Shower mixer
Model: RF19604A

3. 3/8" Kitchen mixer
Model: RF19605A

Body Markings:

Richford

Expiry Date:

31 August 2022	(for model RF19601)
25 July 2022	(for model RF19604A)
24 July 2022	(for model RF19605A)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,


A handwritten signature in black ink, appearing to read 'm h' with a stylized flourish at the end.

(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



RF19601



RF19604A



RF19605A