



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (7) in WSD 3321/17 Pt.1 T/J(604)

2 November 2017

Approval of "GTB" Sensor Taps

Your letter ref. L17-068 dated 29 May 2017 and subsequent submission received by this department on 4 October 2017 refer.

Having considered the test report ref. J21324r1 issued on 26 September 2017 by Nutek Systems (HK) Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: HDSafe Technologies Co Ltd

Country of Origin: China

Brand: GTB

Details of Fitting: 1/2" Deck mounted sensor basin tap with 1 no. of flexible hose approved by UK's WRAS under ref. 1708710

Model: HD507AC & HD507DC

Body Markings: GTB

Expiry Date: 10 April 2022 (for tap + hose)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

“A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply.” AND

“The main voltage operated sensor valves should comply with the electricity safety regulation for applications in bathroom, toilet etc.”

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



HD507AC / HD507DC