



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(1290)

10 November 2017

Approval of “GUANGDONG 南粵牌” Galvanized Steel Pipes

Your letters dated 29 September 2017 and 25 October 2017 refer.

Having considered the test reports ref. BC-SUMMARY-2017-4 and BC-SUMMARY-2017-5 both issued on 16 October 2017 by Castco Testing Centre Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Guangzhou Municipal Guangdong Steel Tube Co Ltd
Country of Origin:	China
Brand:	Guangdong 南粵牌
Details of Pipes:	Galvanized steel pipe
Size:	25mm, 50mm, 200mm
Body Markings:	廣州南粵 GB/T3091-2008 DN(Inch) x 6000mm
Expiry Date:	29 December 2021

Proviso: The pipes can only be used in fresh water fire service plumbing system.

This Authority hereby permits the use of the above pipes in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only