



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(1322)

10 November 2017

Approval of “BERMAD” Pressure Reducing Valves

Your letters ref. WSD/AP-09102017-1 and WSD/AP-09102017-1(1) dated 9 October 2017 and 12 October 2017 respectively refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
Bermad	420 Series (50mm)	172620ST170514	6 Oct 2017
Bermad	420 Series (65mm)	172620ST170514(1)	6 Oct 2017
Bermad	420 Series (80mm)	172620ST170514(2)	6 Oct 2017
Bermad	420 Series (100mm)	172620ST170514(3)	6 Oct 2017
Bermad	420 Series (150mm)	172620ST170514(4)	6 Oct 2017
Bermad	420 Series (200mm)	172620ST170514(5)	6 Oct 2017

Having considered the above test reports issued by the Fugro Technical Services Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Bermad CS Ltd

Country of Origin: Israel

Brand: Bermad

Details of Fittings: Ductile iron pressure reducing valve with epoxy powder coating in blue, green or red under WRAS approval no. 1701509

Model: 420 Series

Size: 50mm, 65mm, 80mm, 100mm, 150mm, 200mm

Body Markings: BERMAD size in inch size in mm ➡

Expiry Date: 31 January 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.


Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



420 Series