



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件  
e-mail      wsdinfo@wsd.gov.hk

電話  
Telephone      2829 4355

圖文傳真  
Facsimile      2824 0578

檔號  
Reference      ( 2 ) in WSD 3321/17 Pt.1 T/J(1357)

16 November 2017

### Approval of "SPENCA" Self Closing Tap

Your letter ref. KS-11409 dated 19 October 2017 refers.

Having considered the test report ref. 171921ST170545A issued on 19 October 2017 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:**      Taizhou Shenhu Sanitary Co Ltd

**Country of Origin:**      China

**Brand:**      Spenca

**Details of Fitting:**      1/2" Self closing tap

**Model:**      E00-2201

**Body Markings:**      *Spenca*®

**Expiry Date:**      15 August 2022

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)  
for Water Authority

c.c.      WSD 3321/1/82   ] - without catalogue  
            ME/MC           ] - with soft copy only



E00-2201