



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/17 Pt.1 T/J(1412)

17 November 2017

Approval of "BRAY" Butterfly Valves

Your letter dated 9 November 2017 refers.

Having considered the test report ref. BC-SUMMARY-2017-117 issued on 1 November 2017 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Bray Controls
Country of Origin:	China
Brand:	Bray
Details of Fitting:	Carbon steel wafer type butterfly valve
Model:	Series 42
Size:	65mm, 80mm, 100mm, 125mm, 150mm, 200mm
Body Markings:	Bray

Expiry Date: 24 September 2022

Proviso: The fittings can only be used in fresh water fire service plumbing systems.

This Authority hereby permits the use of the above fittings in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Series 42