



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(1403)

28 November 2017

Approval of "KC" UPVC Fittings

Your letters dated 6 November 2017 and 17 November 2017 refer.

Having considered the test reports ref. 172397ST170630A, 172397ST170630(1)A and 172397ST170630(2)A all issued on 14 November 2017 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kubota ChemiX Co Ltd

Country of Origin: Japan

Brand: KC

Details of Fittings: uPVC fittings in grey colour

Description	Size (mm)
90° Elbow	16, 25, 40, 50, 65, 100, 150
45° Elbow	16, 20, 25, 30, 40, 50
90° Elbow Female Thread	16, 20
Tee	20, 30, 50, 65, 75, 100

Description	Size (mm)
Reducing Tee	20x16, 25x16, 25x20, 30x20, 40x16, 40x20, 50x20, 50x25, 50x40, 75x25, 75x40, 75x50, 100x50, 100x75, 150x100
Reducer	20x16, 25x16, 25x20, 30x20, 30x25, 40x30, 50x40, 65x50, 75x50, 100x75, 150x100

Body Markings:



Expiry Date:

17 August 2022

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.


Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



90° Elbow



45° Elbow



90° Elbow Female Thread



Tee



Reducing Tee



Reducer