



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (8) in WSD 3321/17 Pt.1 T/J(1097)

12 December 2017

Approval of "MIKI" Sensor Tap

Your letter dated 11 August 2017 and subsequent submission received by this department on 5 December 2017 refer.

Having considered the test report ref. J21133r2 issued on 23 November 2017 by Nutek System (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Dragon Fine Design Ltd

Country of Origin: China

Brand: MIKI

Details of Fitting: 1/2" Electronic sensor tap supplied with one piece of KAIDING CITY HUALING HOSES CO., LTD HL RANGE OF HOSE ASSEMBLIES approved by UK's WRAS under ref 1409957

Model: MIKI-2201

Body Markings:

MIKI

Expiry Date:

5 February 2022 (for tap)
30 September 2019 (for hose)

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



MIKI-2201