



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(1454)

13 December 2017

Approval of "KITZ" Butterfly Valves

Your letters ref. BEP/EME/LET/MF277 and BEP/EME/LET/MF278 dated 22 November 2017 and 29 November 2017 respectively refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Kitz	G-PN16DJE (200mm)	J22063A	7 Nov 2017
Kitz	G-PN16DJE (250mm)	J22063B	7 Nov 2017
Kitz	G-PN16DJE (300mm)	J22063C	7 Nov 2017
Kitz	G-PN16DJE (350mm)	J22063D	7 Nov 2017
Kitz	G-PN16DJE (400mm)	J22063E	7 Nov 2017
Kitz	G-PN16DJE (450mm)	J22063F	7 Nov 2017
Kitz	G-PN16DJE (500mm)	J22063G	7 Nov 2017
Kitz	G-PN16DJE (600mm)	J22063H	7 Nov 2017

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kitz

Country of Origin: Thailand

Brand: Kitz

Details of Fittings: Ductile iron wafer type butterfly valve

Model: G-PN16DJE

Size: 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm

Body Markings: Kitz size in inch size in DN DI

Expiry Date: 13 September 2022

Proviso: The fittings can only be used in non-potable water plumbing system.

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



G-PN16DJE