



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/17 Pt.1 T/J(1507)

8 January 2018

Approval of “DECO” Ductile Iron Pipes

Your letter ref. SL20171208 dated 14 December 2017 refers.

Having considered the test reports ref. BC-SUMMARY-2017-130 and 170515-0266 issued on 18 November 2017 and 12 December 2017 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Xinxing Ductile Iron Pipes Co Ltd
Country of Origin:	China
Brand:	Deco
Details of Pipes:	K9 & K12 Ductile iron pipe (Push in joint T-type) with internal cement mortar lining
Size:	80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm

Body Markings:

For K9 Ductile iron pipe:
DECO DUCTILE IRON PIPE BSEN545
(DN) x (Length) K9 (Class) Zn 200
(Production Code)

For K12 Ductile iron pipe:
DECO DUCTILE IRON PIPE BSEN545
(DN) x (Length) K12 (Class) Zn 200
(Production Code)

Expiry Date:

24 July 2022

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only