



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(1499)

11 January 2018

Approval of "AFA" Check Valves

Your letters ref. BEP/EME/LET/MF280 and BEP/EME/LET/MF282 dated 5 December 2017 and 29 December 2017 respectively refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
AFA	977-SS (65mm)	J22272Ar1	22 Dec 2017
AFA	977-SS (80mm)	J22272Br1	22 Dec 2017
AFA	977-SS (100mm)	J22272Cr1	20 Dec 2017
AFA	977-SS (125mm)	J22272Dr1	22 Dec 2017
AFA	977-SS (150mm)	J22272Er1	20 Dec 2017
AFA	977-SS (200mm)	J22272Fr1	20 Dec 2017
AFA	977-SS (250mm)	J22272Gr1	20 Dec 2017
AFA	977-SS (300mm)	J22272Hr1	22 Dec 2017
AFA	977-SS (350mm)	J22272Ir1	22 Dec 2017
AFA	977-SS (400mm)	J22272Jr1	22 Dec 2017

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jiwa

Country of Origin: China

Brand: AFA

Details of Fittings: Stainless steel wafer type check valve

Model: 977-SS

Size: 65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm

Body Markings: AFA size in DN

Expiry Date: 2 November 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply system mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



977-SS