



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(1442)

25 January 2018

Approval of "TOZEN" Expansion Joints

Your letters ref. TLL/M783/17 and TLL/M786/18 dated 17 November 2017 and 12 January 2018 respectively refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Tozen	Twinflex300 (32mm)	J22165Ar1	4 Jan 2018
Tozen	Twinflex300 (40mm)	J22165Br1	4 Jan 2018
Tozen	Twinflex300 (50mm)	J22165Cr1	4 Jan 2018
Tozen	Twinflex300 (65mm)	J22165Dr1	4 Jan 2018
Tozen	Twinflex300 (80mm)	J22165Er1	4 Jan 2018
Tozen	Twinflex300 (100mm)	J22165Fr1	4 Jan 2018
Tozen	Twinflex300 (125mm)	J22165Gr1	4 Jan 2018
Tozen	Twinflex300 (150mm)	J22165Hr1	4 Jan 2018

Having considered the above test reports issued by Nutek Systems (HK) Limited and test report ref. EN0161202-24 issued on 24 February 2017 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tozen Corporation

Country of Origin: China

Brand: Tozen

Details of Fittings: Twin sphere rubber expansion joint

Model: Twinflex300

Size: 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 125mm, 150mm

Body Markings: TOZEN TWINFLEX size in mm size in inch

Expiry Date: 23 January 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,


(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Twinflex300