



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(1521)

25 January 2018

Approval of "LCY" Expansion Joints

Your letters ref. PS-WSD17009(1) and PS-WSD17009(3) dated 20 December 2017 and 5 January 2018 respectively refer.

Having considered the test report ref. BC-SUMMARY-2017-133 issued on 18 December 2017 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Light Way Metals Co Ltd

Country of Origin: Taiwan

Brand: LCY

Details of Fitting: Stainless steel expansion joint

Model: LCY-JF-850SGC(PN25)

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm,
80mm, 100mm, 150mm, 200mm

Body Markings: LCY LCY-JF-850SGC

Expiry Date: 1 December 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply system mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



LCY-JF-850SGC(PN25)